ADDENDUM NO. 2

TO: ALL BIDDERS OF RECORD

PROJECT: Bearpaw Lake FAS Road and Parking Improvement

FWP PROJECT #: 7113721

DATE: August 29, 2013

FROM: Kevin McDonnell.

Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications are as follows:

CLARIFICATIONS:

• Section 02240 Rock Bar Removal Part 3.1A

High water event this spring has narrowed the access trail mentioned in 3.1A. If the contractor does not feel the site can be safely accessed over this trail the contractor may utilize an alternate access paralleling the foot trail immediately to the east of the spillway.

If the alternate access is used the contractor will repair damage to vegetation per items 3.3D and 3.3E. The same as if the specified access trail was used.

• Section 02250 Crib Access Steps

Since the access steps will be fit to existing site conditions the exact dimensions are not known. The estimated horizontal length is 22 feet and the vertical length is 12 feet.

MODIFICATIONS:

• Plan Sheet 2:

Barrier Post Detail – Change: 7" DIA. MIN. to 6" DIA. MIN.

August 29, 2013 Page 1